# **ELEVATOR CONTROL UNIT (ECU)**



### APPLICATION

□ The ECU (Elevator Control Unit) is the device that interfaces between the SCU and the ECDs. Each ECU has 16 built-in relays to control elevator functions. Up to 4 ECUs can be connected to a single SCU, giving the Millennium system the capability of controlling up to 64,000 floor relays.

### FEATURES

- Controls as many as 10 elevator cars and 64 floors when four units are cascaded on a single SCU.
- 10,000 user capacity. When four units are connected together on a single SCU, 40,000 users are available.

#### ECU

#### EC2-101190

Elevator Control Unit 120V.

## SPECIFICATIONS

#### **Input Power Requirements**

120 VAC input on a 2 Amp unswitched dedicated circuit (EC2-101190)
For international power

requirements there is a 240 VAC model available (EC2-101191)

#### Programmable Relays

• Each ECU employs 16 programmable single pole, Form C relays that are rated for 5 Amps at 24 VDC

#### All Events History Buffer

• 2000 events, stored in RAM memory with a minimum of 24 hours backup

#### **Fuse Protection**

• A 2 Amp slow blow fuse protects the AC input

#### Alarm Monitoring

• Monitors up to 4 independent Normally Closed (non-supervised) alarm inputs. The circuit must have a break time of at least 500ms for the alarm to trigger

#### Priority Event Buffer:

• 100 software selectable priority events (alarms, com fail, etc.) These events are stored on-board if the ECU is off-line with the host computer. Stored events are sent to the host computer once communications are re-established

#### Cover Tamper Switch

• On-board integrated tamper switch

#### Keyswitch Override

• Used by Fire Department personnel to override the access control system during an emergency

#### **Operating Temperature**

• 14° to 104°F (-10° to 40°C) less than 90% non-condensing humidity

#### **Dimensions**

- 14.25" X 12.25" X 4.25" @ 20lbs
- 36.2 X 31.1 X 10.8 cm @ 9.1kg

#### **Certification / Listing**

• UL 294



sales@mgiaccess.com

#### 16 Tech Circle Natick, MA 01760